



Red and White Fire Protection Ltd

4-6 Spicer Street

0800 058 8946

St Albans

info@redandwhitefireprotection.co.uk

Hertfordshire

www.redandwhitefireprotection.co.uk

AL3 4QP

FIRE EXTINGUISHER SERVICE INSPECTION CERTIFICATE

CUSTOMER: ST ANDREWS CHURCH

Address: SILVER STREET, ENFIELD, EN1 3EG

This is to certify that a representative of Red and White Fire Protection Ltd has recently visited your premises to inspect your portable fire extinguishers and that they were serviced as required by British Standard BS 5306: part 3 and have been installed according to British Standard BS 5306: part 8. Certification is reliant on all extinguishers being in good, working and serviceable condition.

Extinguisher Type Serviced	Quantity	Serviceable
CO2 2KG	8	✓
WATER 9 LTR	6	✓
FOAM 6 LTR	2	✓
FIRE BLANKET	1	✓

Date of Issue: 12/10/2018

Next Service Due: OCT 2019

Job reference no: STA0041018

Engineer: 009



Registered Company in England and Wales: 9256508

Registered VAT Number: 199199043



Red and White Fire Protection Ltd

4-6 Spicer Street

0800 058 8946

St Albans

info@redandwhitefireprotection.co.uk

Hertfordshire

www.redandwhitefireprotection.co.uk

AL3 4QP

GUIDANCE TO CLIENTS

Apart from the non-conforming extinguishers recorded, all portable fire extinguishers have been inspected and serviced in accordance with BS 5306 Part 3, BAFE Scheme BSP101.

Clients however, are reminded of the recommendations given in BS 5306 Part 3 for their own inspection:

It is recommended that regular visual inspections of all extinguishers be carried out by the user or user's representative. The frequency of inspections by the user should be not less than monthly and, when circumstances require, inspections should be carried out more frequently.

NOTE 1 The Fire Safety: An Employers Guide [10] information leaflet for employers, which is published by the Home Office as guidance for operating within the Fire Precautions (Workplace) Regulations [2] and [3], suggests that good practice is to determine whether the extinguisher has been operated and to check for damage on a weekly basis.

Inspections should include checks that:

- a) each extinguisher is located in the designated place;
- b) each extinguisher is unobstructed and visible;
- c) the operating instructions of each extinguisher are clean and legible and face outwards;
- d) each extinguisher has not been operated and is not obviously damaged;
- e) the reading of any pressure gauge or indicator fitted to an extinguisher is within operational safety limits;
- f) the seals and tamper indicators of each extinguisher are not broken or missing.

The user should arrange for corrective action, where necessary.

NOTE 2 Employers in charge of a workplace have obligations under the Fire Precautions (Workplace) Regulations [2] and [3]. Regulation 6 requires that, where it is necessary to provide extinguishing equipment to safeguard employees in the event of fire, this equipment has to be maintained in an efficient state, in efficient working order and in good repair.



Registered Company in England and Wales: 9256508

Registered VAT Number: 199199043